

30 DAY WALKTHROUGH INSPECTIONS

NORTH DAKOTA DEPARTMENT OF ENVIRONMENTAL QUALITY DIVISION OF WASTE MANAGEMENT – UNDERGROUND STORAGE TANK PROGRAM SFN 62147 (02-2023)

Telephone: 701-328-5166 Fax: 701-328-5200 Email: <u>ndust@nd.gov</u> Website: <u>https://deg.nd.gov/wm</u>

Owners and operators of underground storage tank (UST) systems must conduct periodic walkthrough inspections of their UST facility. These inspections are conducted to ensure essential equipment is operating properly. The North Dakota Department of Environmental Quality's Underground Storage Tank Program has developed a "30-Day Walkthrough Inspection Checklist" in order to assist UST owners and operators with this requirement. Inspections are required on a 30-day basis and must be documented to be in compliance.

Initial each box below the date of inspection to indicate that the device/system was inspected and found to be operating properly on that date. If the 30-day inspection results indicate a potential leak in your underground storage tank system, the reason for the leak must be investigated and corrective action taken to address the source. In addition, if you suspect a release, it must be reported to the North Dakota Department of Environmental Quality's Underground Storage Tank Program at 701.328.5166.

Facility Name	Facility Location Address	ND UST Facility ID						
Person Performing or Overseeing Inspection								

Year	Date of Inspection	Jan	Feb	Mar	Apr	Мау	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	Inspect for the proper operation of your release ions of potential leaks in the underground storage												
Release Detection Records records.	: Review and keep current release detection												
Spill Buckets: Ensure spill buckets are clean, not damaged, and empty of liquid and debris.													
Double-Walled Spill Buckets: Check for leaks in the interstitial space.													
Fill Cap: Check fill cap to make sure it is securely on the fill pipe.													
Recommended: Inspect all monitoring ports and other access points to make sure that the covers and caps are tightly sealed and locked.													
Recommended for Dispenser Hoses, Nozzles, and Breakaways: Inspect for loose fittings, deterioration, improper functioning and signs of leakage. Call your tank contractor to repair obvious problems.													
Recommended for Spill and Overfill Response Supplies: Ensure you have available onsite appropriate supplies for cleaning up spills or overfills (i.e., an absorbent such as cat litter or floor dry).													