

FACILITY INFORMATION

CONTAINMENT SUMP INTEGRITY TESTING – HYDROSTATIC TESTING METHOD

NORTH DAKOTA DEPARTMENT OF ENVIRONMENTAL QUALITY

DIVISION OF WASTE MANAGEMENT – UNDERGROUND STORAGETANK PROGRAM

SFN 62222 (09-2022)

Telephone: 701-328-

Telephone: 701-328-5166 Fax: 701-328-5200 Email: <u>ndust@nd.gov</u>

Clear Form

Website: https://deq.nd.gov/wm

This procedure is used to test the leak integrity of containment sumps which include piping sumps and under dispenser containment sumps. This procedure is not used to test spill buckets. See PEI/RP1200-17, Section 6.5 for test method.

Facility Name			Telephone Number			
Address			City		State	ZIP Code
SUMP TESTER INFORM	MATION	1				
Name of Tester			Name of Company			
Address			City		State	ZIP Code
Telephone Number			Email Address			
SUMP TEST						
Date of Test:						
Containment Sump ID						
Containment sump material						
Liquid and debris removed from sump?	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Visual inspection (No cracks, loose parts or separation of containment sump)	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Containment sump depth						
Height from bottom to top of highest penetration						
Starting Water Level						
Test Start Time						
Ending Water Level						
Test End Time						
Test Period (minimum Test Time: 1 Hour)**						
Water Level Change						
Pass/Fail Criteria: Must pass visual inspection and water level drop of less than 1/8 inch.						
Test Results	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail

^{**} Accelerated precision hydrostatic tests may be used. See PEI/RP1200-17, Section 6.6.